

# Annual Environmental Report

2023



Carrigtwohill

D0044-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 CARRIGTOHILL WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - CARRIGTOHILL WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - CARRIGTOHILL WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CARRIGTOHILL WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO CARRIGTOHILL WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 5.2 SHELLFISH IMPACT ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

**7 APPENDIX**

7.1 AMBIENT MONITORING SUMMARY

7.2 OTHER

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER

This Annual Environmental Report has been prepared for D0044-01, Carrigtwohill, in Cork in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Carrigtwohill WWTP with a Plant Capacity PE of 30000, the treatment type is 3NP - Tertiary N&P removal .

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0500D0044SW001	Carrigtwohill WWTP	Treated	Compliant	N/A

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

**There are no Licence Specific Reports included in this AER.**

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 CARRIGTOHILL WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - CARRIGTOHILL WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
BOD, 5 days with Inhibition (Carbonaceo mg/l)	4	92	59
COD-Cr mg/l	4	421	239
Total Nitrogen mg/l	4	18	11
Total Phosphorus (as P) mg/l	4	3.85	1.97
Suspended Solids mg/l	4	170	145
Hydraulic Capacity	N/A	18727	5965

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0500D0044SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	12	N/A	N/A	56	Pass
Suspended Solids mg/l	35	87.5	N/A	12	N/A	N/A	2.77	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	25	50	N/A	12	N/A	N/A	3.92	Pass
Total Oxidised Nitrogen (as N) mg/l	20	24	N/A	12	N/A	N/A	2.57	Pass
pH pH units	9	9	N/A	12	N/A	N/A	7.43	Pass
Ammonia-Total (as N) mg/l	5	6	N/A	12	N/A	N/A	1.13	Pass
Total Phosphorus (as P) mg/l	1	1.2	N/A	12	1	N/A	0.330	Pass
ortho-Phosphate (as P) - unspecified mg/l	0.5	0.6	N/A	12	N/A	N/A	0.173	Pass
Benzo(b)fluoranthene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.003	
2,4-Dichlorophenol µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Acenaphthylene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Chloroform µg/l	N/A	N/A	N/A	2	N/A	N/A	2.74	
Cyanide (unspecified) µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Chloromethane µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Naphthalene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.023	
Dibenzo(a,h)anthracene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
E. Coli no./100mls	N/A	N/A	N/A	2	N/A	N/A	13490	
Chloride mg/l	N/A	N/A	N/A	2	N/A	N/A	72	
Mercury - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Nickel - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	2.45	
Phenanthrene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.107	
Isoproturon µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Linuron µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Sum 3_IWW: HCHs µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	



Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>Total Hardness (as CaCO3) mg/l</b>	N/A	N/A	N/A	2	N/A	N/A	152	
<b>Vanadium - filtered µg/l</b>	N/A	N/A	N/A	2	N/A	N/A	N/A	
<b>2,6-Dichlorobenzamide µg/l</b>	N/A	N/A	N/A	2	N/A	N/A	N/A	
<b>Simazine µg/l</b>	N/A	N/A	N/A	2	N/A	N/A	N/A	
<b>Boron - filtered µg/l</b>	N/A	N/A	N/A	2	N/A	N/A	397	
<b>Barium - filtered µg/l</b>	N/A	N/A	N/A	2	N/A	N/A	8.28	
<b>Acenaphthene µg/l</b>	N/A	N/A	N/A	2	N/A	N/A	0.032	
<b>Hexachlorobutadiene µg/l</b>	N/A	N/A	N/A	2	N/A	N/A	N/A	
<b>Dichlobenil µg/l</b>	N/A	N/A	N/A	2	N/A	N/A	N/A	
<b>Tetrachloroethylene µg/l</b>	N/A	N/A	N/A	2	N/A	N/A	N/A	
<b>Enterococci (Intestinal) no./100mls</b>	N/A	N/A	N/A	2	N/A	N/A	90	
<b>Copper - unspecified µg/l</b>	N/A	N/A	N/A	2	N/A	N/A	3.00	
<b>Cobalt - filtered µg/l</b>	N/A	N/A	N/A	2	N/A	N/A	0.906	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Selenium - filtered µg/l	N/A	N/A	N/A	2	N/A	N/A	11	
Pyrene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.040	
Trichloroethene (all isomers) µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Tin - filtered µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Total Nitrogen mg/l	N/A	N/A	N/A	12	N/A	N/A	6.08	
Benzo(k)fluoranthene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Benzo(g,h,i)perylene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Antimony - filtered µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Arsenic - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Diuron µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Isodrin µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Hexachlorobenzene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Fluorene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.043	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Faecal coliforms no./100mls	N/A	N/A	N/A	2	N/A	N/A	3217	
Chromium - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Fluoranthene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.048	
MCPA µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Lead - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Indeno(1,2,3-c,d)pyrene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Glyphosate µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Zinc - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	16	
Atrazine µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Carbon Tetrachloride µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Benzo(a)pyrene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.002	
Benzene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Cadmium - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Anthracene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.009	
1,2-Dichloroethane µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Chrysene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.008	
Ethylbenzene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Toluene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Xylenes (Total) µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Fluoride mg/l	N/A	N/A	N/A	2	N/A	N/A	0.224	
Dieldrin µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Conductivity @20°C µS/cm	N/A	N/A	N/A	2	N/A	N/A	552	
Molybdenum - filtered µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Mecoprop µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Polyaromatic Hydrocarbons (PAH) - Sum µg/l	N/A	N/A	N/A	2	N/A	N/A	0.325	
Trichlorobenzene (all isomers) µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

## Cause of Exceedance(s):

Not applicable

## Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

### 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0500D0044SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Downstream	179127, 70773	TW05003153LE6001	No	No	No	Yes	Moderate

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

## Significance of Results:

The coastal/transitional ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CARRIGTOHILL WWTP

### 2.1.4.1 Treatment Efficiency Report - Carrigtohill WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	4703	1170	75
TN	25409	21584	15
SS	347470	9831	97
cBOD	138803	13899	90
COD	570763	197638	65

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - Carrigtohill WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Carrigtohill WWTP	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	20250

Carrigtohill WWTP	
DWF to the Treatment Plant (m <sup>3</sup> /day)	6750
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	18727
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	5965
Organic Capacity (PE) - As Constructed	30000
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	9480
Organic Capacity (PE) - Remaining	20520
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - CARRIGTOHILL WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Landfill Leachate (delivered by tanker)	8570.81	Weight (Tonnes)		0.39	No	Yes	Yes
Industrial / Commercial Sludge	4863.56	Weight (Tonnes)		0.22	No	No	No

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>Domestic /Septic Tank Sludge</b>	8288.5	Volume (m3)		0.38	No	No	No



## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2023.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
<b>Spillage</b>	Broken Sewer Pipe	No	No
<b>Uncontrolled release</b>	Broken Sewer Pipe	No	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2023	2
Number of Incidents reported to the EPA via EDEN in 2023	2
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2023 (No. of events)	Total volume discharged in 2023 (m3)	Monitoring Status
<b>SW01</b>	179911,72605	Yes	Medium Significance	Meeting Criteria	Unknown	Unknown	Monitored
<b>SW003</b>	181277,72257	Yes	Medium Significance	Not Meeting Criteria	Unknown	Unknown	Monitored
<b>TBC</b>	180600,73562	Yes	Medium Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>TBC</b>	181544,73040	Yes	Medium Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>TBC</b>	181544,73040	Yes	Medium Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>TBC</b>	181133,72310	Yes	Medium Significance	Meeting Criteria	Unknown	Unknown	Monitored

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2023 (No. of events)	Total volume discharged in 2023 (m3)	Monitoring Status
-	-, -	No	Medium Significance	Meeting Criteria	Unknown	Unknown	Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	No
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NAY)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0044-SIP:01</b>	Installation of new WWTP to meet ELVs as specified in Schedule A	C	31/12/2016	Yes	Works Completed		
<b>D0044-SIP:02</b>	Installation of storm water holding tank (SW003)	C	31/12/2016	Yes	Works Completed		
<b>D0044-SIP:03</b>	Installation of storm water holding tank (SW004)	C	31/12/2016	Yes	Works Completed		
<b>D0044-SIP:04</b>	Nutrient removal to meet ELVs as specified in Schedule A	C	31/12/2016	Yes	Works Completed		
<b>D0044-SIP:05</b>	SW002 Primary Discharge Point to be discontinued	C	31/12/2016	Yes	Works Completed		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

#### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>No additional improvements planned at this time.</b>				

### **4.2.3 SEWER INTEGRITY RISK ASSESSMENT**

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
D0044-01-Priority Substances Assessment	Yes	No
D0044-01-Shellfish Impact Assessment	Yes	No

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No



I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 09/04/2024

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Head of Environmental Regulation.

# 7 APPENDIX

<b>Appendix</b>
<b>Appendix 7.1 - Ambient monitoring summary</b>
<b>Appendix 7.2 - Other</b>

### Ambient Points

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	EPA Feature Coding Tool code	Receiving Waters Designation (Y/N)				WFD Status
			Bathing Water	Drinking Water	FWPM	Shellfish	
TW05003153LE6001	179127.21, 70773.28	TPEFF0500D0044SW001	No	No	No	Yes	Moderate

### Ambient Impact Assessment Table

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	%EQS
Ammonia - Total (as N) mg/l	-	-	TW05003153LE6001	0.069		
cBOD - 5 days with inhibition mg/l	-	-	TW05003153LE6001	2.545	4	
Total Oxidised Nitrogen (as N) mg/l	-	-	TW05003153LE6001	0.7125		
Temperature	-	-	TW05003153LE6001	13.425		
Dissolved Oxygen % saturation	-	-	TW05003153LE6001	99.6	70-130	
Ortho-Phosphate (as P) – unspecified mg/l	-	-	TW05003153LE6001	0.0165	0.06	
pH	-	-	TW05003153LE6001	8		

Raw Ambient Data

Downstream								
Monitoring point	Date	Ammonia-Total (as N) mg/l	BOD - 5 days (Total) mg/l	Dissolved Oxygen %sat	ortho-Phosphate (as P) - unspecified mg/l	pH	Temperature	Total Oxidised Nitrogen (as N) mg/l
TW05003153LE6001	01/03/2023	0.134	0.5	100.5	0.01	8	8.2	0.58
	04/05/2023	0.0175	2.8	94.4	0.005	8	12.9	0.24
	10/08/2023	0.0175	1.1	68.8	0.03	7.9	18.3	1.01
	04/10/2023	0.107	0.5	93.3	0.021	7.9	14.3	1.02
<b>mean</b>		0.069	1.225	89.25	0.0165	7.95	13.425	0.7125
<b>95%ile</b>		0.12995	2.545	99.585	0.02865	8	17.7	1.0185