

Annual Environmental Report

2023



Cloyne

D0298-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 CLOYNE WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - CLOYNE WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - CLOYNE WWTP -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CLOYNE WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO CLOYNE WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 5.2 SHELLFISH IMPACT ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER

This Annual Environmental Report has been prepared for D0298-01, Cloyne, in Cork in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Cloyne WWTP with a Plant Capacity PE of 1400, the treatment type is 2 - Secondary treatment .

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0500D0298SW001	Cloyne WWTP	Treated	Non-Compliant	BOD, 5 days with Inhibition (Carbonaceo mg/l COD-Cr mg/l Suspended Solids mg/l Total Nitrogen mg/l

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 CLOYNE WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - CLOYNE WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
COD-Cr mg/l	12	1286	524
Total Nitrogen mg/l	12	116	64
Suspended Solids mg/l	12	1336	283
BOD, 5 days with Inhibition (Carbonaceo mg/l)	12	401	199
Hydraulic Capacity	N/A	767	357

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is greater than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0500D0298SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	50	100	N/A	12	8	N/A	60	Fail
Total Nitrogen mg/l	15	18	N/A	12	10	9	27	Fail
BOD, 5 days with Inhibition (Carbonaceous) mg/l	10	20	N/A	12	9	5	18	Fail
Suspended Solids mg/l	10	25	N/A	12	11	7	27	Fail
pH pH units	9	9	N/A	12	N/A	N/A	7.79	Pass
Acenaphthylene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.004	
Benzo(a)pyrene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.007	
Barium - filtered µg/l	N/A	N/A	N/A	2	N/A	N/A	11	
1,2-Dichloroethane µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Ammonia-Total (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	24	
2,4-Dichlorophenol µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Chloride mg/l	N/A	N/A	N/A	2	N/A	N/A	193	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Isodrin µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Cyanide (unspecified) µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Indeno(1,2,3-c,d)pyrene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.003	
Chrysene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.020	
Diuron µg/l	N/A	N/A	N/A	2	N/A	N/A	0.154	
Glyphosate µg/l	N/A	N/A	N/A	2	N/A	N/A	0.327	
Hexachlorobenzene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Cobalt - filtered µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	12	N/A	N/A	1.82	
Mercury - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	0.170	
Molybdenum - filtered µg/l	N/A	N/A	N/A	2	N/A	N/A	2.19	
MCPA µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Lead - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	0.243	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Sum 3_IWW: HCHs µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Mecoprop µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Polyaromatic Hydrocarbons (PAH) - Sum µg/l	N/A	N/A	N/A	2	N/A	N/A	2.15	
Xylenes (Total) µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Vanadium - filtered µg/l	N/A	N/A	N/A	2	N/A	N/A	42	
Nickel - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Phenanthrene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.614	
Trichlorobenzene (all isomers) µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Boron - filtered µg/l	N/A	N/A	N/A	2	N/A	N/A	93	
Acenaphthene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.081	
Antimony - filtered µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Atrazine µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Carbon Tetrachloride µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Anthracene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.056	
Chromium - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Fluoride mg/l	N/A	N/A	N/A	2	N/A	N/A	0.435	
Dieldrin µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Hexachlorobutadiene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Linuron µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Dibenzo(a,h)anthracene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Isoproturon µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Zinc - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	54	
Simazine µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Pyrene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.354	
Total Hardness (as CaCO3) mg/l	N/A	N/A	N/A	2	N/A	N/A	275	
Trichloroethene (all isomers) µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Benzo(b)fluoranthene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.007	
Chloromethane µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Ethylbenzene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Total Oxidised Nitrogen (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	3.31	
Cadmium - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Benzene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Arsenic - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Benzo(k)fluoranthene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.005	
Benzo(g,h,i)perylene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Chloroform µg/l	N/A	N/A	N/A	2	N/A	N/A	0.973	
Conductivity @20°C µS/cm	N/A	N/A	N/A	2	N/A	N/A	1324	
Copper - unspecified µg/l	N/A	N/A	N/A	2	N/A	N/A	19	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Fluoranthene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.462	
Tin - filtered µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Toluene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Dichlobenil µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Fluorene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.123	
Selenium - filtered µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
Naphthalene µg/l	N/A	N/A	N/A	2	N/A	N/A	0.401	
Tetrachloroethylene µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	
2,6-Dichlorobenzamide µg/l	N/A	N/A	N/A	2	N/A	N/A	N/A	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Refer to the incidents section of this report.

Significance of Results:

The WWTP is not in compliance with the ELV, as set out in the WWDL. The impact on receiving waters is assessed further in section 2.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0500D0298SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
There is no Ambient monitoring required by the WWDL.							

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CLOYNE WWTP

2.1.4.1 Treatment Efficiency Report - Cloyne WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
COD	65732	7520	89
TN	8007	3326	58
TP	N/A	N/A	N/A
cBOD	25022	2236	91
SS	35554	3423	90

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - Cloyne WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Cloyne WWTP	
Peak Hydraulic Capacity (m³/day) - As Constructed	315
DWF to the Treatment Plant (m³/day)	105
Current Hydraulic Loading - annual max (m³/day)	767
Average Hydraulic loading to the Treatment Plant (m³/day)	356.7
Organic Capacity (PE) - As Constructed	1400
Organic Capacity (PE) - Collected Load (peak week)^{Note1}	2125
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - CLOYNE WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Landfill Leachate (delivered by tanker)	90	Volume (m3)		0.06	No	No	No

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2023.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	WWTP upgrade required to meet ELV	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2023	1
Number of Incidents reported to the EPA via EDEN in 2023	1
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2023 (No. of events)	Total volume discharged in 2023 (m3)	Monitoring Status
TBC	191396,67968	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
SW2CLYN	191123,67812	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
TBC	191572,68031	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A

SWO Summary	
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0298-SIP:01	SWO2CLYN to comply with definition of SWO as set out in DoEHLG procedures & criteria	A	30/06/2012	Yes	At Planning Stage		Feasibility study and concept design being undertaken
D0298-SIP:02	Upgrading of SWO to comply with the criteria outlined in the DoEHLG "Procedures and Criteria in relation to Storm Water Overflows, 1995" arising from the assessment	C	30/06/2012	Yes	At Planning Stage		Feasibility study and concept design being undertaken

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/N/A/Y)	Status of Works	Timeframe for Completing the Work	Comments
	required under Condition 4.10 (SWOICLYN)						

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
D0298-01-Priority Substances Assessment	Yes	No
D0298-01-Shellfish Impact Assessment	Yes	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 10/04/2024

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Head of Environmental Regulation.

7 APPENDIX

There are no Appendices included