

Annual Environmental Report

2023



Falcarragh

D0343-01

CONTENTS

- 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER**
 - 1.1 ANNUAL STATEMENT OF MEASURES
 - 1.2 TREATMENT SUMMARY
 - 1.3 ELV OVERVIEW
 - 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER
- 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**
 - 2.1 FALCARRAGH WWTP - UNTREATED DISCHARGE
 - 2.1.1 EFFLUENT MONITORING SUMMARY - FALCARRAGH WWTP -
 - 2.1.2 AMBIENT MONITORING SUMMARY FOR UNTREATED DISCHARGE -
- 3 COMPLAINTS AND INCIDENTS**
 - 3.1 COMPLAINTS SUMMARY
 - 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS
- 4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**
 - 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
 - 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT
- 5 LICENCE SPECIFIC REPORTS**
 - 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 6 CERTIFICATION AND SIGN OFF**
 - 6.1 SUMMARY OF AER CONTENTS
- 7 APPENDIX**
 - 7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER

This Annual Environmental Report has been prepared for D0343-01, Falcarragh, in Donegal in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

1.2 TREATMENT SUMMARY

- Currently there is no treatment provided at Falcarragh. Please refer to section 4 for details of the Programme of Improvements.

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0600D0343SW001	FALCARRAGH WWTP	Untreated	Non-Compliant	BOD, 5 days with Inhibition (Carbonaceous) mg/l and Suspended Solids mg/l

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1.1 EFFLUENT MONITORING SUMMARY -

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Suspended Solids mg/l	N/A	N/A	50%	6	5	N/A	55	Fail
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	N/A	N/A	20%	6	4	N/A	42	Fail
E. Coli MPN/100ml	N/A	N/A	N/A	2	N/A	N/A	1699000	
Faecal coliforms cfu/100ml	N/A	N/A	N/A	2	N/A	N/A	1143500	
Nitrate (as N) mg/l	N/A	N/A	N/A	6	N/A	N/A	0.318	
Conductivity @20°C µS/cm	N/A	N/A	N/A	6	N/A	N/A	533	
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	6	N/A	N/A	1.39	
Total Oxidised Nitrogen (as N) mg/l	N/A	N/A	N/A	6	N/A	N/A	0.368	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
pH pH units	N/A	N/A	N/A	6	N/A	N/A	7.33	
Ammonia-Total (as N) mg/l	N/A	N/A	N/A	6	N/A	N/A	15	
COD-Cr mg/l	N/A	N/A	N/A	6	N/A	N/A	141	
Nitrite (as N) mg/l	N/A	N/A	N/A	6	N/A	N/A	0.034	
Enterococci (Intestinal) cfu/100ml	N/A	N/A	N/A	2	N/A	N/A	75000	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

There is no treatment provided at Falcarragh.

Significance of Results:

The WWTP is not compliant with ELVs set in the Wastewater Discharge Licence.

2.1.2 AMBIENT MONITORING SUMMARY FOR THE UNTREATED DISCHARGE TPEFF0600D0343SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Downstream	191859, 433757	CW06007064BS1001	No	No	No	No	High

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

Significance of Results:

The coastal/transitional ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2023.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Specified % Reduction Value not achieved	WWTP upgrade required to meet ELV	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2023	1
Number of Incidents reported to the EPA via EDEN in 2023	1
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2023 (No. of events)	Total volume discharged in 2023 (m3)	Monitoring Status
SW001	192243,432200	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
TBC	192798,431875	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	TBC
TBC	-, -	Yes	-	Not yet Assessed	Unknown	Unknown	TBC

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes

SWO Summary

Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?

No

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0343-SIP:01	Decommissioning of current primary discharge SW001	C	31/12/2015	Yes	At Planning Stage	2030	
D0343-SIP:02	Improvement works to ensure compliance with emission percentage reductions specified in Schedule A: Discharges and Discharge Monitoring.	C	31/12/2015	Yes	At Planning Stage	2030	
D0343-SIP:03	Improvement works to increase the organic and hydraulic treatment capacity of the plant to ensure compliance with Condition 1.7 of this licence.	C	31/12/2015	Yes	At Planning Stage	2030	

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0343-SIP:04	The licensee will provide and maintain a mechanism by which the primary discharge from the Falcarragh agglomeration is restricted to periods of high tide only in Ballyness Bay to ensure compliance with Condition 5.6 of this licence.	C	31/12/2015	No	At Planning Stage	2030	

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
D0343-01-Priority Substances Assessment	Yes	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 13/11/2024

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

Falcarragh 2023 AMBIENT MONITORING SUMMARY

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	EPA Feature Coding Tool code	Receiving Waters Designation (Y/N)				WFD Status
			Bathing Water	Drinking Water	FWPM	Shellfish	
Downstream Monitoring Point	191859, 433757	CW06007064BS1001	No	No	No	No	High

Ambient Impact Assessment Table

Parameter Name	Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS (Mean)
BOD mg/l	CW06007064BS1001	2.75	4
Ammonia (as N) mg/l	CW06007064BS1001	0.32	
ortho-Phosphate (as P) - unspecified mg/l	CW06007064BS1001	NT	0.06

Falcarragh D0343-01 Ambient Monitoring Summary

Month	Category	Entity	Station	Date	Ammonia (as N)	BOD	Dissolved Oxygen % Saturation	E.coli	Intestinal Enterococci	Faecal Coliforms	Total Oxidised Nitrogen N	Salinity	pH	Suspended Solids
March	Coastal Water Body	Ballyness Bay	Falcarragh, Point 1	28-Mar-23	0.67	4	100.7	0	8	6	0.5	31.3	8	64
May	Coastal Water Body	Ballyness Bay	Falcarragh, Point 1	09-May-23	0.58	1	100.7	1	12	0	0.5	34.2	8	146
September	Coastal Water Body	Ballyness Bay	Falcarragh Point 1	06-Sep-23	0.02	3	91.6	100	8	100	0.5	33.4	8	33
November	Coastal Water Body	Ballyness Bay	Falcarragh, Point 1	07-Nov-23	0.04	3	101.3	100	63	100	0.5	27.22	8	11

