

Annual Environmental Report

2023



Ballinagar

D0362-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 BALLINAGAR WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - BALLINAGAR WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - BALLINAGAR WWTP -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR BALLINAGAR WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO BALLINAGAR WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

- 7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER

This Annual Environmental Report has been prepared for D0362-01, Ballinagar, in Offaly in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no capital works, significant changes or operational changes undertaken in 2023.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Ballinagar WWTP with a Plant Capacity PE of 1000, the treatment type is 3P - Tertiary P removal.

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2500D0362SW001	Ballinagar WWTP	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 BALLINAGAR WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - BALLINAGAR WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	7	258	83
COD-Cr mg/l	7	628	195
Suspended Solids mg/l	7	207	60
Ammonia-Total (as N) mg/l	7	49	20
ortho-Phosphate (as P) - unspecified mg/l	7	4.31	0.999
pH pH units	7	7.90	7.47
Hydraulic Capacity	N/A	456	100

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2500D0362SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	7	N/A	N/A	18	Pass
Suspended Solids mg/l	35	87.5	N/A	7	N/A	N/A	5.14	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	20	40	N/A	7	N/A	N/A	1.40	Pass
pH pH units	6	9	N/A	7	N/A	N/A	7.62	Pass
Ammonia-Total (as N) mg/l	2.6	3.12	N/A	7	N/A	N/A	0.101	Pass
ortho-Phosphate (as P) - unspecified mg/l	1.5	1.8	N/A	7	N/A	N/A	0.382	Pass

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2500D0362SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	205522, 175636	RS25B360100	No	No	No	No	Moderate
Downstream	243357, 223167	RS25T030040	No	No	No	No	Poor

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient Monitoring Summary**.

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS at the upstream and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ortho-P concentration downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

As per the 3rd Cycle Draft Lower Shannon (Brosna) Catchment Report (HA 25A), the significant pressures on the Tullamore_020 waterbody are Agriculture, Peat and Industry. The Ballinagar WWTP although listed on Cycle 2, is not listed as a significant pressure in the Cycle 3 report.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - BALLINAGAR WWTP

2.1.4.1 Treatment Efficiency Report - Ballinagar WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
SS	1888	222	88
COD	6175	781	87
cBOD	2622	61	98

Note: The above data is based on sample results for the number of dates reported.

2.1.4.2 Treatment Capacity Report Summary - Ballinagar WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Ballinagar WWTP	
Peak Hydraulic Capacity (m³/day) - As Constructed	675
DWF to the Treatment Plant (m³/day)	225
Current Hydraulic Loading - annual max (m³/day)	456
Average Hydraulic loading to the Treatment Plant (m³/day)	100.12
Organic Capacity (PE) - As Constructed	1000
Organic Capacity (PE) - Collected Load (peak week)^{Note1}	476
Organic Capacity (PE) - Remaining	524
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - BALLINAGAR WWTP

'Other inputs' to the waste water treatment plant are summarised in the table below.

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2023.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Abatement equipment off-line	Plant or equipment breakdown at WWTP	No	Yes

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2023	1
Number of Incidents reported to the EPA via EDEN in 2023	1
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2023 (No. of events)	Total volume discharged in 2023 (m ³)	Monitoring Status
SW2	244148 223816	Yes	Low Significance	Not Meeting Criteria	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m ³)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	Yes
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NAY)	Status of Works	Timeframe for Completing the Work	Comments
D0362-SIP:01	Relocate the primary discharge from Ballinagar Stream to the Tullamore River	C	31/12/2019	Yes	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period.
D0362-SIP:02	SW001 Primary Discharge Point - Convert to Storm Water Overflow	C	31/12/2019	Yes	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period.

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

N/A

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
Priority Substances Assessment	Yes	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	Yes
List reason e.g. changes to monitoring requirements	Ambient Monitoring Location Changes
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 27/02/2024

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Ambient Monitoring Summary

Ballinagar Ambient Monitoring Summary 2023

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)				Current WFD Status	Mean (mg/l)		
			Bathing Water	Drinking Water	FWPM	Shellfish		cBOD	o-Phosphate (as P)	Ammonia (as N)
Upstream Monitoring Point	205522, 175636	RS25B360100	No	No	No	No	Moderate	1.42	0.028	0.164
Downstream Monitoring Point	243357, 223167	RS25T030040	No	No	No	No	Poor	1.42	0.034	0.096
<i>Difference</i>								<i>0.00</i>	<i>0.005</i>	<i>-0.069</i>
EQS								1.500	0.035	0.065
% of EQS								-0.281%	15.678%	-105.585%

Ballinagar Ambient Monitoring Data 2023

			Temperature	pH	BOD	COD	Suspended solids	Total Ammonia as N	Ortho-Phosphate as P	DO	DO
Station	Station Reference	Sample Date	Degrees C	pH units	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	% Sat
Upstream	RS25B360100	11/01/2023	4	7.46	1.1	55	33	0.081	0.023	4.4	40.5
Upstream	RS25B360100	01/03/2023	6	8.13	< 1	28	4.5	0.037	0.018	8.1	63.1
Upstream	RS25B360100	02/03/2023	6.3	8.13	1.1	34	< 2	0.081	0.026	9.1	69.1
Upstream	RS25B360100	04/05/2023	12.5	8.03	1.2	43	3.5	< 0.02	0.034	9.3	98.1
Upstream	RS25B360100	09/05/2023	12	7.89	1.1	53	3.5	0.049	0.022	10.1	100.1
Upstream	RS25B360100	17/05/2023	16	7.93	1.4	47	7.5	0.041	0.014	9.94	96.4
Upstream	RS25B360100	25/05/2023	12	8.02	2.8	34	< 2	0.025	0.022	5.5	40.5
Upstream	RS25B360100	07/06/2023	18.1	8.06	1	< 20	< 2	0.023	0.061	5.5	88.2
Upstream	RS25B360100	15/06/2023	17.1	7.82	1.4	38	15	1.67	0.033	7.27	79.1
Upstream	RS25B360100	28/06/2023	18.1	7.93	3	37	10	0.097	0.025	5.3	80.1
Upstream	RS25B360100	29/06/2023	15.9	7.97	< 1	39	4.5	0.05	0.028	7.99	80.6
Upstream	RS25B360100	13/07/2023	16	8.02	< 1	24	< 2	0.078	< 0.02	6.44	83.1
Upstream	RS25B360100	18/07/2023	16.2	7.84	1.6	55	18.4	0.063	0.037	8	101.3
Upstream	RS25B360100	14/08/2023	17.2	7.7	< 1	42	< 2	0.046	0.053	7.22	93.2
Upstream	RS25B360100	15/08/2023	18.1	8.03	1.2	37	13.6	0.035	0.024	9	94.5
Upstream	RS25B360100	16/08/2023	15.5	7.91	< 1	< 20	2.5	0.044	0.012	7.66	76.4
Upstream	RS25B360100	13/09/2023		8	3.7	32	< 2	0.36	0.038		
		Mean	13.813	7.934	1.420	36.840	7.323	0.1644	0.0285	7.551	80.269
		95%ile	18.100	8.130	3.140	55.000	21.320	0.622	0.055	9.980	100.400

			Temperature	pH	BOD	COD	Suspended solids	Total Ammonia as N	Ortho-Phosphate as P	DO	DO
Station	Station Reference	Sample Date	Degrees C	pH units	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	% Sat
Downstream	RS25T030040	11/01/2023	4.2	7.45	2	49	13	0.051	0.067	7.6	52.1
Downstream	RS25T030040	01/03/2023	6	8.14	< 1	30	14	0.036	0.039	8.2	63.6
Downstream	RS25T030040	02/03/2023	6.2	8.12	< 1	36	< 2	0.044	< 0.02	9.4	70.3
Downstream	RS25T030040	04/05/2023	12.8	8.06	< 1	< 20	< 2.5	< 0.02	0.025	9.1	97.1
Downstream	RS25T030040	09/05/2023	12	7.96	< 1	< 20	< 2.5	0.024	0.018	10	100.3
Downstream	RS25T030040	17/05/2023	13	8.04	1	< 20	< 2.5	< 0.02	0.008	11.74	113
Downstream	RS25T030040	25/05/2023	12.4	7.99	2.3	35	< 2	0.027	< 0.02	10.1	80.1
Downstream	RS25T030040	07/06/2023	18.3	8.09	< 1	< 20	< 2	0.062	0.093	12.1	104.1
Downstream	RS25T030040	15/06/2023	16.1	7.88	1	< 20	8	0.025	0.023	11.48	114.9
Downstream	RS25T030040	28/06/2023	18.3	8.04	3.7	42	10.8	0.13	0.025	11.4	100.1
Downstream	RS25T030040	29/06/2023	14	7.89	< 1	< 20	4.5	< 0.02	0.022	10.39	101.1
Downstream	RS25T030040	13/07/2023	16.4	8.05	3.7	41	< 2	0.46	< 0.02	11.2	100.2
Downstream	RS25T030040	18/07/2023	16.3	7.77	< 1	55	< 2	0.26	0.088	9.9	102.2
Downstream	RS25T030040	14/08/2023	17.4	8.04	1.6	43	22.8	0.043	0.041	12.4	101.4
Downstream	RS25T030040	15/08/2023	18.4	7.95	< 1	41	19.6	0.032	0.038	11	103.6
Downstream	RS25T030040	16/08/2023	14.2	7.83	< 1	21	< 2.5	0.031	0.011	9.14	90.7
Downstream	RS25T030040	13/09/2023	1.4	8	2.4	29	8	0.36	0.037		
			Mean	12.788	7.959	1.416	29.815	6.755	0.0957	10.322	93.425
			95%ile	18.320	8.124	3.700	50.200	20.240	0.380	12.175	113.475

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of LOD/sqrt(2) was used in calculating the mean and 95%ile concentrations.