

Annual Environmental Report

2023



Allenwood

D0493-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 ALLENWOOD WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - ALLENWOOD WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - ALLENWOOD WWTP
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR ALLENWOOD WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO ALLENWOOD WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

- 7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER

This Annual Environmental Report has been prepared for D0493-01, Allenwood, in Kildare in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no capital works, significant changes or operational changes undertaken in 2023.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Allenwood WWTP with a Plant Capacity PE of 1510, the treatment type is 3P - Tertiary P removal.

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1400D0493SW001	Allenwood WWTP	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 ALLENWOOD WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - ALLENWOOD WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
ortho-Phosphate (as P) - unspecified mg/l	11	0.940	0.300
Suspended Solids mg/l	11	626	131
Total Nitrogen mg/l	11	75	31
COD-Cr mg/l	11	957	222
BOD, 5 days with Inhibition (Carbonaceous) mg/l	11	178	91
Ammonia-Total (as N) mg/l	11	23	10
Total Phosphorus (as P) mg/l	11	11	2.36
pH pH units	11	7.88	7.43
Hydraulic Capacity	N/A	1034	683

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1400D0493SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	10	N/A	N/A	21	Pass
Suspended Solids mg/l	35	87.5	N/A	11	N/A	N/A	2.71	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	20	40	N/A	11	N/A	N/A	3.27	Pass
pH pH units	6	9	N/A	11	N/A	N/A	7.33	Pass
Ammonia-Total (as N) mg/l	2	2.4	N/A	11	N/A	N/A	0.614	Pass
ortho-Phosphate (as P) - unspecified mg/l	1	1.2	N/A	11	N/A	N/A	0.044	Pass

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Total Oxidised Nitrogen (as N) mg/l	N/A	N/A	N/A	11	N/A	N/A	5.11	
Total Nitrogen mg/l	N/A	N/A	N/A	11	N/A	N/A	7.59	
Chromium - unfiltered µg/l	N/A	N/A	N/A	1	N/A	N/A	11	
Conductivity @20°C µS/cm	N/A	N/A	N/A	11	N/A	N/A	813	
Total Phosphorus (as P) mg/l	N/A	N/A	N/A	11	N/A	N/A	0.137	
Nitrate (as N) mg/l	N/A	N/A	N/A	11	N/A	N/A	4.95	
Nitrite (as N) mg/l	N/A	N/A	N/A	11	N/A	N/A	0.200	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF1400D0493SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	276606, 225692	RS14S010047	No	No	No	No	Poor
Downstream	276240, 225494	RS14S010049	No	No	No	No	Poor

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient Monitoring Summary**.

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS at the upstream and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - ALLENWOOD WWTP

2.1.4.1 Treatment Efficiency Report - Allenwood WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TN	8332	2408	71
SS	35525	860	98
COD	60213	6401	89
TP	639	43	93
cBOD	24516	1038	96

Note: The above data is based on sample results for the number of dates reported.

2.1.4.2 Treatment Capacity Report Summary - Allenwood WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Allenwood WWTP	
Peak Hydraulic Capacity (m³/day) - As Constructed	1013
DWF to the Treatment Plant (m³/day)	338
Current Hydraulic Loading - annual max (m³/day)	1034
Average Hydraulic loading to the Treatment Plant (m³/day)	683
Organic Capacity (PE) - As Constructed	1510
Organic Capacity (PE) - Collected Load (peak week)^{Note1}	1330
Organic Capacity (PE) - Remaining	180
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - ALLENWOOD WWTP

'Other inputs' to the waste water treatment plant are summarised in the table below.

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2023.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	SWO exceptional rainfall and overflow expected	No	No
Uncontrolled release	SWO exceptional rainfall and overflow expected	No	Yes
Abatement equipment off-line	Screen not operating	No	Yes

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	SWO exceptional rainfall and overflow expected	No	Yes
Uncontrolled release	SWO exceptional rainfall and overflow expected	No	Yes
Uncontrolled release	SWO exceptional rainfall and overflow expected	No	Yes
Abatement equipment off-line	Dosing pump failure or maintenance at WWTP	No	Yes
Uncontrolled release	SWO exceptional rainfall and overflow expected	No	Yes
Uncontrolled release	Emergency overflow caused by power failure	No	Yes
Uncontrolled release	SWO exceptional rainfall and overflow expected	No	Yes

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2023	10
Number of Incidents reported to the EPA via EDEN in 2023	10
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2023 (No. of events)	Total volume discharged in 2023 (m ³)	Monitoring Status
SW002	276520 225676	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m ³)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0493-SIP:01	Upgrading of Storm Water Overflow to comply with the criteria outlined in the DoEHLG "Procedures and Criteria in relation to Storm Water overflows, 1995", in accordance with Condition 5.2	C	31/12/2014	Yes	Works Completed		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

N/A

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
There is no Licence Specific Report Required in this AER Annual Review.		

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 28/02/2024

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Ambient Monitoring Summary

Allenwood Ambient Monitoring Summary 2023

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)				Current WFD Status	Mean (mg/l)		
			Bathing Water	Drinking Water	FWPM	Shellfish		cBOD	o-Phosphate (as P)	Ammonia (as N)
Upstream Monitoring Point	276606, 225692	RS14S010047	No	No	No	No	Poor	2.000	0.070	1.017
Downstream Monitoring Point	276240, 225494	RS14S010049	No	No	No	No	Poor	1.818	0.069	0.839
<i>Difference</i>								-0.182	-0.001	-0.178
EQS								1.500	0.035	0.065
% of EQS								-12.121%	-3.377%	-274.126%

Allenwood Ambient Monitoring Summary 2023

Upstream Results											
Station Name	Sample Date	Temperature oC	pH pH units	BOD mg/l	COD mg/l	SS mg/l	Total Nitrogen mg/l	Total Phosphorus mg/l	Ammonia mg/l	Ortho-Phosphate mg/l	DO mg/l
Upstream	18/01/2023	9.8	7.55	2	41	1	3.8	0.034	0.52	0.013	10.32
Upstream	15/02/2023	14.4	7.43	2	64	13	2.74	0.121	0.99	0.06	8.88
Upstream	08/03/2023	12.8	7.42	2	58	2	2.86	0.082	0.7	0.07	10.22
Upstream	05/04/2023	14	7.21	2	77	4	2.31	0.047	1.13	0.04	9.8
Upstream	13/06/2023	19.4	7.32	1	15	4	3.2	0.09	0.39	0.01	8.13
Upstream	20/07/2023	15.5	7.69	2	92	1	3.9	0.075	1.49	0.06	7.98
Upstream	04/08/2023	15.6	7.61	3	99	2	3.95	0.095	1.46	0.06	8.26
Upstream	20/09/2023	16.1	7.68	2	94	4	3.47	0.082	1.45	0.07	8.29
Upstream	25/10/2023	15.6	7.57	2	104	4	4.54	0.053	1.23	0.05	8.04
Upstream	22/11/2023	13.8	7.53	2	72	1	2.98	0.057	1.02	0.02	9.42
Upstream	08/12/2023	6.8	7.61	2	51	15	3.05	0.088	0.81	0.04	10.04
	Mean	13.982	7.511	2.000	69.727	4.636	3.345	0.075	1.017	0.045	9.035
	95%ile	17.750	7.685	2.500	101.500	14.000	4.245	0.108	1.475	0.070	10.270

Downstream Results											
Station Name	Sample Date	Temperature oC	pH pH units	BOD mg/l	COD mg/l	SS mg/l	Total Nitrogen mg/l	Total Phosphorus mg/l	Ammonia mg/l	Ortho-Phosphate mg/l	DO mg/l
Downstream	18/01/2023	10.1	7.54	2	42	1	3.72	0.056	0.54	0.027	11.02
Downstream	15/02/2023	14.6	7.45	2	29	7	2.96	0.124	0.56	0.1	9.61
Downstream	08/03/2023	12.9	7.51	2	32	2	3.63	0.081	0.41	0.07	10.4
Downstream	05/04/2023	14.1	7.19	2	67	3	4.22	0.052	0.96	0.05	9.66
Downstream	13/06/2023	19.7	7.31	1	14	2	3.68	0.059	0.43	0.1	8.17
Downstream	20/07/2023	16	7.67	1	72	3	6.16	0.089	1.13	0.06	7.86
Downstream	04/08/2023	15.7	7.59	2	99	2	4.31	0.082	1.39	0.05	7.77
Downstream	20/09/2023	16.1	7.63	2	90	2	8.56	0.109	1.46	0.09	7.75
Downstream	25/10/2023	15.9	7.59	2	84	2	4.21	0.073	1.05	0.06	7.99
Downstream	22/11/2023	14.1	7.56	2	61	4	3.12	0.108	0.79	0.06	8.96
Downstream	08/12/2023	6.9	7.72	2	37	4	3.65	0.179	0.51	0.09	9.96
	Mean	14.191	7.524	1.818	57.000	2.909	4.384	0.092	0.839	0.069	9.014
	95%ile	17.900	7.695	2.000	94.500	5.500	7.360	0.152	1.425	0.100	10.710

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of LOD/sqrt(2) was used in calculating the mean and 95%ile concentrations.