

# Annual Environmental Report

2019



Athlone

D0007-01

## Athlone 2019 Ambient Monitoring Summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)				Current WFD Status
			Bathing Water	Drinking Water	FWPM	Shellfish	
Upstream Monitoring Point	204112, 240975	RS26S021720	No	No	No	No	Poor
Downstream Monitoring Point	204008, 240237	RS26S021725	No	Yes	No	No	Poor

\*It should be noted that Irish Waste is unable to access the downstream sampling location as prescribed under Schedule B.3 Ambient Monitoring. The lands adjacent to all the sample locations are underwater for at least a period of 6-8 months of the year. Westmeath County Council/Irish Water are in the process of selecting a suitable alternative downstream monitoring point.

## 2019 Athlone Ambient Monitoring Data

Upstream Results							
Date		Ammonia (mg/l) *	Ortho P (mg/l) *	BOD (mg/l)	D.O (% Sat)	D.O (mg/l)	pH (mg/l)
08/01/19	U/S	0.014	0.014	0.5			8.2
05/02/19	U/S	0.032	0.014	1.4	92.2	11.08	8.3
20/03/19	U/S	0.005	0.01	0.5	94.8		8.3
09/04/19	U/S	0.017	0.014	0.5	92.9	10.19	8.3
08/05/19	U/S	0.018	0.01	0.5			8.4
11/06/19	U/S	0.02	0.005	4.7	96.8	9.73	8.4
02/07/19	U/S	0.013	<0.005	0.5			8.4
13/08/19	U/S	0.014	<0.005	0.5			8.3
03/09/19	U/S	0.019	0.007	1	95.8	9.11	8.4
08/10/19	U/S	0.027	0.01	1	93.3	9.37	8.4
05/11/19	U/S	0.016	0.008	1	10.63	10.63	8.3
04/12/19	U/S	0.018	0.019	1.8	94.9	11.41	8.3
<b>Mean</b>		<b>0.018</b>	<b>0.011</b>	<b>1.158</b>	<b>83.9</b>	<b>10.22</b>	<b>8.33</b>
<b>95%ile</b>		<b>0.029</b>	<b>0.017</b>	<b>3.105</b>	<b>96.5</b>	<b>11.31</b>	<b>8.40</b>

\* Where the concentration in the result is less than the limit of detection (LOD), a value of 50% of the LOD was used in calculating the mean and 95%ile concentrations.

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 ATHLONE WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - ATHLONE WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - ATHLONE WWTP
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR ATHLONE WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO ATHLONE WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 5.2 TOXICITY OF FINAL EFFLUENT
- 5.3 TOXICITY/LEACHATE MANAGEMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

**7 APPENDIX**

7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER

This Annual Environmental Report has been prepared for D0007-01, Athlone, in Westmeath in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no capital works, significant changes or operational improvements undertaken this year.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Athlone WWTP with a Plant Capacity PE of 36000, the treatment type is 3P - Tertiary P removal

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF3200D0007SW001	Athlone WWTP	Treated	Compliant	N/A

## 1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 ATHLONE WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - ATHLONE WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	12	18.5	6.27
Total Nitrogen mg/l	12	61.5	28.25
COD-Cr mg/l	12	1290	448.59
BOD - 5 days (Total) mg/l	12	672	212.26
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	507	183.51
Suspended Solids mg/l	12	1030	270.47
Hydraulic Capacity	N/A	16951	9482

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.



## Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

### 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF3200D0007SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	14	N/A	N/A	34.99	Pass
<b>Suspended Solids mg/l</b>	35	87.5	N/A	14	1	N/A	7.54	Pass
<b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b>	25	50	N/A	14	1	N/A	4.57	Pass
<b>pH pH units</b>	6-9	6-9	N/A	14	N/A	N/A	7.37	Pass
<b>Ammonia-Total (as N) mg/l</b>	5	6	N/A	14	N/A	N/A	0.41	Pass
<b>Total Phosphorus (as P) mg/l</b>	2	2.4	N/A	14	N/A	N/A	0.19	Pass
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	N/A	N/A	N/A	14	N/A	N/A	0.14	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Dissolved Oxygen mg/l	N/A	N/A	N/A	1	N/A	N/A	7.82	
Temperature °C	N/A	N/A	N/A	2	N/A	N/A	12.24	
Conductivity 20 C µS/cm	N/A	N/A	N/A	14	N/A	N/A	569.12	
Nitrate (as N) mg/l	N/A	N/A	N/A	14	N/A	N/A	5.31	
Total Nitrogen mg/l	N/A	N/A	N/A	14	N/A	N/A	8.41	
Total Oxidised Nitrogen (as N) mg/l	N/A	N/A	N/A	13	N/A	N/A	5.77	
Dissolved Oxygen % Saturation	N/A	N/A	N/A	1	N/A	N/A	76.1	
Nitrite (as N) mg/l	N/A	N/A	N/A	14	N/A	N/A	0.09	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

### Cause of Exceedance(s):

Not applicable

### Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE

### TPEFF3200D0007SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
<b>Upstream</b>	204112, 240975	RS26S021706	No	No	No	No	Poor
<b>Downstream</b>	204008, 240237	RS26S021725	No	Yes	No	No	Poor

\*It should be noted that Irish Waste is unable to access the downstream sampling location as prescribed under Schedule B.3 Ambient Monitoring. The lands adjacent to all the sample locations are underwater for at least a period of 6-8 months of the year. Westmeath County Council/Irish Water are in the process of selecting a suitable alternative downstream monitoring point.

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

### Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

Based on ELV compliance, it is not considered that the discharge from the wastewater treatment plant is having an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - ATHLONE WWTP

### 2.1.4.1 Treatment Efficiency Report - Athlone WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	21688	655	97
COD	1552582	117995	92
TN	97772	28371	71
cBOD	635137	15415	98
SS	936104	25425	97

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - Athlone WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Athlone WWTP	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	20250
DWF to the Treatment Plant (m <sup>3</sup> /day)	6750
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	16951

Athlone WWTP	
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	9482
Organic Capacity (PE) - As Constructed	36000
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	22470
Organic Capacity (PE) - Remaining	13530
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - ATHLONE WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Landfill Leachate (delivered by tanker)	8169	Volume (m3)	99.47	0.26	Yes	Yes	Yes
Waterworks Sludge	24569	Volume (m3)	299.17	0.71	Yes	Yes	Yes

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
24	Blocked Sewer	0	24

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
<b>Abatement Equipment offline</b>	Plant or equipment breakdown at WWTP	1	No	Yes
<b>Uncontrolled release</b>	EO caused by ragging or blocking	1	No	Yes

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2019	2
Number of Incidents reported to the EPA via EDEN in 2019	2
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
S.O.1	204156, 241041	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.2	204828, 241689	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.3	203943, 241685	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.4	204328, 242628	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.5	203685, 242655	Yes	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.6	202670, 241883	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored



WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
S.O.7	203984, 241226	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.8	203629, 240854	Yes	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.9	203198, 241781	Yes	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.10	203111, 241984	Yes	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.11	203390, 241990	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.12	203902, 241098	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.13	203968, 241688	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.14	203716, 242200	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.15	204040, 240941	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.16	204627, 241342	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.17	204719,	Yes	Unknown	Not yet	Unknown	Unknown	Not

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
	241347			Assessed			Monitored
S.O.18	204824, 241254	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
S.O.19	204156, 241041	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0007-SIP:01</b>	Installation of Abbey Road to Golden Island tunnel sewer	C	31/05/2011	Yes	At Planning Stage	01/06/2024	
<b>D0007-SIP:02</b>	Installation of new Coosan pumping station and installation of new rising main and new sewer to Abbey Road	C	31/05/2011	Yes	At Planning Stage	01/06/2024	
<b>D0007-SIP:03</b>	Installation of storm water storage tank at Golden Island pumping station and associated rising main to WWTP	C	31/05/2011	Yes	At Planning Stage	01/06/2024	
<b>D0007-SIP:04</b>	Rehabilitation of sewers including installation of Roslevin Lawns surface water culvert , completion of A1 river improvement scheme and installation of Retreat Road surface water sewer	C	31/12/2014	Yes	At Planning Stage	01/06/2024	

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0007-SIP:05</b>	SW019 (204156E, 241041N) (formerly S.O.1)	C	31/05/2011	Yes	At Planning Stage	01/06/2024	
<b>D0007-SIP:06</b>	Discharge to discontinue: SW010, Location 203111E 241984N (Athlone Canal)	A	30/11/2011	Yes	At Planning Stage	01/06/2024	
<b>D0007-SIP:07</b>	Discharge to discontinue: SW014, Location 203716E 242200N (River Shannon)	A	30/11/2011	Yes	At Planning Stage	01/06/2024	
<b>D0007-SIP:08</b>	SW015 (204040E, 240941N) formerly (S.O.15)	C	30/11/2011	Yes	At Planning Stage	01/06/2024	
<b>D0007-SIP:09</b>	Discharge to discontinue: SW003, Location - 203943E 241685N (River Shannon)	A	31/05/2011	Yes	At Planning Stage	01/06/2024	
<b>D0007-SIP:10</b>	Discharge to discontinue: SW004, Location - 204328E 242628N (River Shannon)	A	31/05/2011	Yes	At Planning Stage	01/06/2024	
<b>D0007-SIP:11</b>	Discharge to discontinue: SW005, Location 203685E 242655N (River Shannon)	A	31/05/2011	Yes	At Planning Stage	01/06/2024	
<b>D0007-SIP:12</b>	SW007 (203984E, 241226N) formerly S.O.7	C	30/11/2011	Yes	At Planning Stage	01/06/2024	
<b>D0007-SIP:13</b>	Discharge to discontinue: SW009, Location 203198E 241781N (Athlone	A	30/11/2011	Yes	At Planning	01/06/2024	

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
	Canal)				Stage		
<b>D0007-SIP:14</b>	Upgrade and replacement of West Bank, West Side, Canal and Siphon sewers, upgrade of sewer connection to Golden Island pumping station and installation of sewer across The Meadows	C	30/11/2011	Yes	At Planning Stage	01/06/2024	
<b>D0007-SIP:16</b>	Upgrade of Golden Island pumping station	C	31/12/2014	Yes	At Planning Stage	01/06/2024	
<b>D0007-SIP:17</b>	Upgrade of WWTP and ancillary works	C	31/12/2014	Yes	Works Completed		

A summary of the status of any improvements identified by under Condition 5.2 is included below.

#### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

### **4.2.3 SEWER INTEGRITY RISK ASSESSMENT**

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2010	No	
Toxicity of Final Effluent	Yes	2010	No	
Toxicity/Leachate Management	Yes	2010	No	

### 5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2010.

### 5.2 TOXICITY OF FINAL EFFLUENT

The Toxicity of Final Effluent Report has been included in the AER 2010.

### 5.3 TOXICITY/LEACHATE MANAGEMENT

The Toxicity/Leachate Management Report has been included in the AER 2010.

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A



I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 05/03/2020

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Katherine Walshe

Acting Head of Environmental Regulation.

## 7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

## Athlone 2019 Ambient Monitoring Summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)				Current WFD Status
			Bathing Water	Drinking Water	FWPM	Shellfish	
Upstream Monitoring Point	204112, 240975	RS26S021720	No	No	No	No	Poor
Downstream Monitoring Point	204008, 240237	RS26S021725	No	Yes	No	No	Poor

\*It should be noted that Irish Waste is unable to access the downstream sampling location as prescribed under Schedule B.3 Ambient Monitoring. The lands adjacent to all the sample locations are underwater for at least a period of 6-8 months of the year. Westmeath County Council/Irish Water are in the process of selecting a suitable alternative downstream monitoring point.

## 2019 Athlone Ambient Monitoring Data

Upstream Results							
Date		Ammonia (mg/l) *	Ortho P (mg/l) *	BOD (mg/l)	D.O (% Sat)	D.O (mg/l)	pH (mg/l)
08/01/19	U/S	0.014	0.014	0.5			8.2
05/02/19	U/S	0.032	0.014	1.4	92.2	11.08	8.3
20/03/19	U/S	0.005	0.01	0.5	94.8		8.3
09/04/19	U/S	0.017	0.014	0.5	92.9	10.19	8.3
08/05/19	U/S	0.018	0.01	0.5			8.4
11/06/19	U/S	0.02	0.005	4.7	96.8	9.73	8.4
02/07/19	U/S	0.013	<0.005	0.5			8.4
13/08/19	U/S	0.014	<0.005	0.5			8.3
03/09/19	U/S	0.019	0.007	1	95.8	9.11	8.4
08/10/19	U/S	0.027	0.01	1	93.3	9.37	8.4
05/11/19	U/S	0.016	0.008	1	10.63	10.63	8.3
04/12/19	U/S	0.018	0.019	1.8	94.9	11.41	8.3
<b>Mean</b>		<b>0.018</b>	<b>0.011</b>	<b>1.158</b>	<b>83.9</b>	<b>10.22</b>	<b>8.33</b>
<b>95%ile</b>		<b>0.029</b>	<b>0.017</b>	<b>3.105</b>	<b>96.5</b>	<b>11.31</b>	<b>8.40</b>

\* Where the concentration in the result is less than the limit of detection (LOD), a value of 50% of the LOD was used in calculating the mean and 95%ile concentrations.