

# Annual Environmental Report

2021



Daingean

D0226-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2021 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 DAINGEAN WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - DAINGEAN WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - DAINGEAN WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR DAINGEAN WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO DAINGEAN WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

- 7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2021 AER

This Annual Environmental Report has been prepared for D0226-01, Daingean, in Offaly in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

The following improvement works were completed at Daingean WWTP in 2021: (i) New inlet works with new inlet chamber plus screen (ii) Relocated and replaced controls kiosk which will allow greater process control for caretaker (iii) Increased sump from 2m<sup>3</sup> to 55m<sup>3</sup> which will reduce the amount of times the plant is washed out from excess surface water entering plant (iv) 3 no. new pumps with new VSD's 1 each feeding aeration and 1 to the storm tank which will allow greater process control and reduce plant wash outs from excess surface water (v) New sludge tank (50m<sup>3</sup>) which will reduce the amount of sludge discharging during storm events and (vi) Ferric dosing tank relocated on site to allow new control kiosk to be installed.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Daingean WWTP with a Plant Capacity PE of 1200, the treatment type is 2 - Secondary treatment.

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2500D0226SW001	Daingean WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l ortho-Phosphate (as P) - unspecified mg/l

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report
There are no Licence Specific Reports included in this AER.

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 DAINGEAN WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - DAINGEAN WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Ammonia-Total (as N) mg/l	5	58.100	41.619
Total Nitrogen mg/l	5	88.400	53.812
Total Phosphorus (as P) mg/l	5	7.200	4.417
pH pH units	5	7.830	7.653
ortho-Phosphate (as P) - unspecified mg/l	5	3.860	2.634
COD-Cr mg/l	7	895.000	299.024
Suspended Solids mg/l	7	416.000	151.859
BOD, 5 days with Inhibition (Carbonaceous) mg/l	7	371.000	120.145
Hydraulic Capacity	N/A	943	363

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

## Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

### 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2500D0226SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included <sup>Note 1</sup>	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	7	N/A	N/A	21	Pass
Suspended Solids mg/l	35	87.5	N/A	7	N/A	N/A	5.45	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	10	20	N/A	7	N/A	N/A	3.2	Pass
pH pH units	6.00	9.00	N/A	7	N/A	N/A	7.73	Pass
Ammonia-Total (as N) mg/l	0.850	1.70	N/A	7	2	1	0.926	Fail
ortho-Phosphate (as P) - unspecified mg/l	0.500	0.600	N/A	7	3	3	0.485	Fail
Nitrite (as N) mg/l	N/A	N/A	N/A	5	N/A	N/A	0.991	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included <sup>Note 1</sup>	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>Conductivity @20°C µS/cm</b>	N/A	N/A	N/A	2	N/A	N/A	961	
<b>Nitrate (as N) mg/l</b>	N/A	N/A	N/A	5	N/A	N/A	21.9	
<b>Total Phosphorus (as P) mg/l</b>	N/A	N/A	N/A	5	N/A	N/A	0.701	
<b>Total Nitrogen mg/l</b>	N/A	N/A	N/A	5	N/A	N/A	26	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Plant/Equipment breakdown at WWTP.

### Significance of Results:

The WWTP is non compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2500D0226SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
<b>Upstream</b>	247721, 226935	RS14D060100	No	No	No	No	Poor
<b>Downstream</b>	248310, 227637	RS14D060200	No	No	No	No	Poor

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: Ammonia-Total (as N) mg/l, ortho-Phosphate (as P) - unspecified mg/l.

The ambient monitoring results do not meet the required EQS at the upstream and downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD, Ortho-P and Ammonia concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status. The WFD status is Poor both upstream and downstream of the WWTP.



## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - DAINGEAN WWTP

### 2.1.4.1 Treatment Efficiency Report - Daingean WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
<b>cBOD</b>	14114.35	292.51	97.93
<b>COD</b>	35128.75	1935.82	94.49
<b>SS</b>	19289.16	498.11	97.42
<b>TN</b>	4497.90	2273.50	49.45
<b>TP</b>	369.17	61.73	83.28

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - Daingean WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Daingean WWTP	
<b>Peak Hydraulic Capacity (m<sup>3</sup>/day) - As Constructed</b>	810
<b>DWF to the Treatment Plant (m<sup>3</sup>/day)</b>	270
<b>Current Hydraulic Loading - annual max (m<sup>3</sup>/day)</b>	943

Daingean WWTP	
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	363
Organic Capacity (PE) - As Constructed	1200
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	1112
Organic Capacity (PE) - Remaining	88
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - DAINGEAN WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>There is no Sludge and Other Input data for the Treatment Plant included in the AER.</b>							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2021.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
<b>Abatement Equipment offline</b>	Plant or equipment breakdown at WWTP	1	No	Yes
<b>Abatement Equipment offline</b>	Plant or equipment breakdown at WWTP	1	No	Yes
<b>Abatement Equipment offline</b>	Plant or equipment maintenance at WWTP	1	No	No

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	Plant or equipment breakdown at WWTP	1	Yes	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2021	4
Number of Incidents reported to the EPA via EDEN in 2021	4
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2021 (No. of events)	Total volume discharged in 2021 (m <sup>3</sup> )	Monitoring Status
TBC	247381, 227231	No	Low	Meeting	Unknown	Unknown	Not Monitored
SW2	247895, 227173	Yes	Low	Not Meeting	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much sewage was discharged via monitored SWOs in the agglomeration in the year (m <sup>3</sup> )?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0226-SIP:01</b>	Upgrade Daingean WWTP to provide tertiary treatment in order to meet the emission limit values specified in Schedule A.1 of this licence.	C	29/07/2009	Yes	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period.

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>No additional improvements planned at this time.</b>				

### **4.2.3 SEWER INTEGRITY RISK ASSESSMENT**

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
Priority Substances Assessment	Yes	2015	No



## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e., have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Has a Technical amendment/licence review application been submitted to the Agency by IW?	No
List reason e.g., additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g., changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 22/04/2022

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Katherine Walshe

Acting Head of Environmental Regulation.

## 7 APPENDIX

Appendix

**Appendix 7.1 - Ambient monitoring summary**

## Daingean 2021 Ambient Monitoring Summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)			
			Bathing Water	Drinking Water	FWPM	Shellfish
Upstream Monitoring Point	247721, 226936	RS14D060100	No	No	No	No
Downstream Monitoring Point	248310, 227637	RS14D060200	No	No	No	No

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Current WFD Status	Mean (mg/l)		
		cBOD	o-Phosphate (as P)	Ammonia (as N)
Upstream Monitoring Point	Poor	1.117	0.040	0.112
Downstream Monitoring Point	Poor	1.687	0.050	0.136
<i>Difference</i>		<i>0.569</i>	<i>0.010</i>	<i>0.024</i>
EQS		1.500	0.035	0.065
% of EQS		37.960%	28.881%	37.112%

## Daingean Ambient Monitoring Data 2021

		Ammonia N	Biological Oxygen Demand	Conductivity @ 20°C	COD Chemical Oxygen Demand	Dissolved Oxygen	Nitrite N	Total Nitrogen N	Dissolved Oxygen % Saturation	Nitrate N	Temp	Total Phosphorus P	Ortho-Phosphate P	pH	Suspended Solids
Station	Sample Date	mg/l	mg/l	µS/cm	mg/l	mg/l	mg/l	mg/l	% Sat.	mg/l	Degrees C	mg/l	mg/l	pH units	mg/l
Upstream	20-Jan-2021	0.103	1.1			7.15			62.5		7.3		0.035	7.4	
Upstream	10-Mar-2021	0.116	1.5	542	34	8.17	0.032	3.3	88.2	2.882	5	0.1	0.07	7.81	< 2.5
Upstream	26-May-2021	0.072	< 1			7.44			66.1		9.9		0.023	7.5	
Upstream	21-July-2021	< 0.02	< 1			10.23			114.1		20.9		< 0.006	7.96	
Upstream	10-Aug-2021	0.23	< 1	468	< 20	10.11	0.089	< 2	111.7	< 1	15.5	0.11	0.047	8.01	< 2
Upstream	25-Nov-2021	0.148	1.1	619		9.13	0.02	2.4	73.2	1.649	5.8	0.09	0.045	7.7	
Upstream	14-Dec-2021	0.099	2		57	11.23	0.067	2.1	115.4	1.9	5.2	< 0.1	0.053	7.73	< 2
	<b>Mean</b>	<b>0.112</b>	<b>1.117</b>	<b>543.000</b>	<b>35.047</b>	<b>9.066</b>	<b>0.052</b>	<b>2.304</b>	<b>90.171</b>	<b>1.785</b>	<b>9.943</b>	<b>0.093</b>	<b>0.040</b>	<b>7.730</b>	<b>1.532</b>
	<b>95%ile</b>	<b>0.205</b>	<b>1.850</b>	<b>611.300</b>	<b>54.700</b>	<b>10.930</b>	<b>0.086</b>	<b>3.165</b>	<b>115.010</b>	<b>2.735</b>	<b>19.280</b>	<b>0.109</b>	<b>0.065</b>	<b>7.995</b>	<b>1.732</b>
		Ammonia N	Biological Oxygen Demand	Conductivity @ 20°C	COD Chemical Oxygen Demand	Dissolved Oxygen	Nitrite N	Total Nitrogen N	Dissolved Oxygen % Saturation	Nitrate N	Temp	Total Phosphorus P	Ortho-Phosphate P	pH	Suspended Solids
Station	Sample Date	mg/l	mg/l	µS/cm	mg/l	mg/l	mg/l	mg/l	% Sat.	mg/l	Degrees C	mg/l	mg/l	pH units	mg/l
Downstream	20-Jan-2021	0.245	1.3			8.52			73.8		7.3		0.033	7.6	
Downstream	10-Mar-2021	0.125	1.3	538	30	9.12	0.043	3.3	89.1	3.114	5.2	0.07	0.04	7.85	< 2.5
Downstream	26-May-2021	0.164	1.2			8.87			80.6		10.8		0.028	7.7	
Downstream	21-July-2021	0.031	4.3			9.42			111.2		19.7		0.01	7.65	
Downstream	10-Aug-2021	0.11	< 1	503	< 20	10.23	0.066	< 2	111.9	< 1	16.6	0.2	0.13	8.16	< 2
Downstream	25-Nov-2021	0.096	1	559		10.3	0.019	2.8	81.1	2.13	5.5	0.06	0.024	7.9	
Downstream	14-Dec-2021	0.18	2		54	11.3	0.12	2.7	116.6	2.3	4.1	< 0.1	0.083	7.85	< 2
	<b>Mean</b>	<b>0.136</b>	<b>1.687</b>	<b>533.333</b>	<b>42.000</b>	<b>9.680</b>	<b>0.062</b>	<b>2.554</b>	<b>94.900</b>	<b>2.063</b>	<b>9.886</b>	<b>0.110</b>	<b>0.050</b>	<b>7.816</b>	<b>1.532</b>
	<b>95%ile</b>	<b>0.226</b>	<b>3.610</b>	<b>556.900</b>	<b>52.800</b>	<b>11.000</b>	<b>0.112</b>	<b>3.225</b>	<b>115.190</b>	<b>2.992</b>	<b>18.770</b>	<b>0.187</b>	<b>0.116</b>	<b>8.082</b>	<b>1.732</b>

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of LOD/sqrt(2) was used in calculating the mean and 95%ile concentrations.