

# Annual Environmental Report

2023



Ballyhaunis

D0069-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 BALLYHAUNIS WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - BALLYHAUNIS WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - BALLYHAUNIS WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR BALLYHAUNIS WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO BALLYHAUNIS WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

## 7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER

This Annual Environmental Report has been prepared for D0069-01, Ballyhaunis, in Mayo in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Ballyhaunis WWTP with a Plant Capacity PE of 4000, the treatment type is 3P - Tertiary P removal .

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2200D0069SW001	Ballyhaunis WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

**There are no Licence Specific Reports included in this AER.**

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 BALLYHAUNIS WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - BALLYHAUNIS WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
<b>BOD, 5 days with Inhibition (Carbonaceo mg/l)</b>	12	375	161
<b>COD-Cr mg/l</b>	12	872	344
<b>Suspended Solids mg/l</b>	12	370	140
<b>Hydraulic Capacity</b>	N/A	3759	1276

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### **Significance of Results:**

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2200D0069SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	12	N/A	N/A	17	Pass
Suspended Solids mg/l	25	62.5	N/A	12	N/A	N/A	4.24	Pass
BOD, 5 days with Inhibition (Carbonaceo mg/l	20	40	N/A	12	N/A	N/A	1.55	Pass
pH pH units	9	9	N/A	12	N/A	N/A	7.76	Pass
Ammonia-Total (as N) mg/l	1	2	N/A	12	7	3	2.45	Fail
ortho-Phosphate (as P) - unspecified mg/l	0.6	0.72	N/A	12	N/A	N/A	0.154	Pass

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Refer to Incident Section of Report.

### Significance of Results:

The WWTP is non compliant with the ELVs set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

### 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2200D0069SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	149294, 278866	RS30D010150	No	No	No	No	Poor
Downstream	149263, 278776	RS30D010160	No	No	No	No	Poor

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: Ammonia-Total (as N) mg/l.

The ambient monitoring results do not meet the required EQS at the upstream and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ammonia (as N) mg/l, concentrations downstream of the effluent discharge is noted.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.



## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - BALLYHAUNIS WWTP

### 2.1.4.1 Treatment Efficiency Report - Ballyhaunis WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
SS	56854	1561	97
COD	139985	6355	95
TP	N/A	N/A	N/A
TN	N/A	N/A	N/A
cBOD	65390	569	99

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - Ballyhaunis WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Ballyhaunis WWTP	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	3000
DWF to the Treatment Plant (m <sup>3</sup> /day)	1000
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	3759

Ballyhaunis WWTP	
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	1276
Organic Capacity (PE) - As Constructed	4000
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	2976
Organic Capacity (PE) - Remaining	1024
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - BALLYHAUNIS WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2023.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
<b>Abatement equipment off-line</b>	Plant or equipment breakdown at WWTP	No	Yes
<b>Breach of ELV</b>	WWTP upgrade required to meet ELV	Yes	Yes
<b>Abatement equipment off-line</b>	Plant or equipment breakdown at WWTP	No	Yes

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	WWTP upgrade required to meet ELV	Yes	Yes
Abatement equipment off-line	Screen not operating	No	Yes
Uncontrolled release	Plant or equipment maintenance at WWTP	No	Yes
Abatement equipment off-line	Plant or equipment breakdown at WWTP	No	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2023	7
Number of Incidents reported to the EPA via EDEN in 2023	7
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2023 (No. of events)	Total volume discharged in 2023 (m3)	Monitoring Status
<b>SW002</b>	149521,279334	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW003</b>	149633,278337	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW005</b>	149312,278832	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>TBC</b>	149520,279334	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m3)?	Unknown

SWO Summary	
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	Unknown

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0069-SIP:01</b>	Improvement works may be required to increase the organic and hydraulic treatment capacity of the plant to ensure compliance with Condition 1.7	C	31/12/2019	Yes	At Planning Stage		

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0069-SIP:02</b>	The plant will require improvement works to ensure compliance with the emission limit values as set out in Schedule A: Discharges & Discharge Monitoring	C	31/12/2019	Yes	At Planning Stage		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

#### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>No additional improvements planned at this time.</b>				

#### 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
<b>D0069-01-Priority Substances Assessment</b>	Yes	No



## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 04/03/2024

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Head of Environmental Regulation.

# 7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

### Ballyhaunis Ambient Points

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	EPA Feature Coding Tool code	Receiving Waters Designation (Y/N)				WFD Status
			Bathing Water	Drinking Water	FWPM	Shellfish	
Upstream Monitoring Point	149294, 278866	RS30D010150	No	No	No	No	Poor
Downstream Monitoring Point	149263, 278776	RS30D010160	No	No	No	No	Poor

### Ambient Impact Assessment Table

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS (Mean)	% EQS
BOD mg/l	RS30D010150	3.6	RS30D010160	1.1	1.5	-166%
Ammonia (as N) mg/l	RS30D010150	0.037	RS30D010160	0.106	0.065	106.1%
ortho-Phosphate (as P) - unspecified mg/l	RS30D010150	0.01	RS30D010160	0.015	0.035	14.2%

### Ballyhaunis D0069-01 Ambient Monitoring Data

Station	Station Reference	River Basin D	Sample Date	Parameter	Ammonia mg/l N	pH pH units	Dissolved Oxygen mg/l	Suspended Solids mg/l	Biological Oxygen mg/l	Ortho-Phosphate mg/l P	Dissolved Oxygen % Saturation	Temperature Degrees C
Ballyhaunis Upstream	RS30DO10150	Western	20-Jan-2023	-	<0.05	7.6	12.52	<5	1.5	<0.05		5.2
Ballyhaunis Downstream	RS30DO10160	Western	20-Jan-2023	-	0.25	7.5	12.64	<5	<1	<0.05		5.8
Ballyhaunis Upstream	RS30DO10150	Western	14-Feb-2023	-	0.05	7.8	11.28	6	5.7	<0.05		10.8
Ballyhaunis Downstream	RS30DO10160	Western	14-Feb-2023	-	0.11	7.6	7.98	<5	<1	<0.05		10.9
Ballyhaunis Downstream	RS30DO10160	Western	23-May-2023	-	0.12	7.8	9.97	5	1.1	<0.01	110.27	20.3
Ballyhaunis Upstream	RS30DO10150	Western	23-May-2023	-	<0.02	8	10	8	<1	<0.01	111.04	20.5
Ballyhaunis Upstream	RS30DO10150	Western	22-June-2023	-	<0.02	8	8.92	<4	<1	<0.01	100.03	13.9
Ballyhaunis Downstream	RS30DO10160	Western	22-June-2023	-	0.06	7.7	8.86	<4	<1	<0.01	99.36	14.2
Ballyhaunis Upstream	RS30DO10150	Western	25-July-2023	-	<0.02	8	8.75	<4	<1	<0.01	95.05	16.3
Ballyhaunis Downstream	RS30DO10160	Western	25-July-2023	-	<0.02	8	8.66	<4	<1	<0.01	95.59	16.2
Ballyhaunis Upstream	RS30DO10150	Western	17-Aug-2023	-	0.02	8	9.93	<4	2.9	<0.01	99.28	15.4
Ballyhaunis Downstream	RS30DO10160	Western	17-Aug-2023	-	0.05	7.7	9.33	<4	<1	<0.01	99.28	15.3
Ballyhaunis Upstream	RS30DO10150	Western	12-Sep-2023	-	<0.02	7.9	9.34	<4	<1	<0.01	84.48	10.9
Ballyhaunis Downstream	RS30DO10160	Western	12-Sep-2023	-	0.15	7.6	8.89	<4	<1	<0.01	80.23	10.8
Ballyhaunis Upstream	RS30DO10150	Western	29-Sep-2023	-	<0.02	7.8	9.37	<4	<1	<0.01	88.5	12.8
Ballyhaunis Downstream	RS30DO10160	Western	29-Sep-2023	-	0.03	7.6	9.18	<4	<1	<0.01	87.48	13.2
Ballyhaunis Downstream	RS30DO10160	Western	16-Nov-2023	-	0.08	7.6	10.42	<4	<1	0.02	91.4	9
Ballyhaunis Upstream	RS30DO10150	Western	16-Nov-2023	-	0.04	7.8	10.52	<4	<1	0.01	91.8	9.3
Ballyhaunis Upstream	RS30DO10150	Western	22-Nov-2023	-	0.04	7.8	10.24	<4	<1	<0.01	90.4	10.3
Ballyhaunis Downstream	RS30DO10160	Western	22-Nov-2023	-	0.11	7.6	10.13	<4	<1	0.01	90.3	10.7